




# WATER VIRTUAL IN-PLANT (VINPLT) TRAINING

Session 4



# Session 4: The 5 L's and Treasure Hunts



# Thank You!

**Sponsor:**




# Today's Agenda

	Homework Recap
	Leaking
	Losing
	Break
	Loading
	Treasure Hunts
	Kahoot!
	Q&A

# HOMework RECAP


POLL



# The 5 L's: Common Water System Inefficiencies

- Leaping
- Looping
- Leaking
- Losing
- Loading

# LEAKING





# Leaking – Problem

High-Pressure Leak



Low-Pressure Leak



**WATER LOSS IS ENERGY LOSS!**

Tim Waldron, “Success Techniques in Applying Water Loss Strategies for Financial Benefits,”  
Workshop on Water and Energy/Water Loss (International Water Association, 2014)




# Water Loss Audit

Volume from Own Sources (corrected for known errors)	System Input Volume	Water Exported (corrected for known errors)	Billed Water Exported				Revenue Water	
		Water Supplied	Authorized Consumption	Billed Authorized Consumption	Billed Metered Consumption		Revenue Water	
					Billed Unmetered Consumption			
				Unbilled Authorized Consumption	Unbilled Unmetered Consumption		Non-revenue Water	
					Unbilled Metered Consumption			
			Water Losses	Apparent Losses	Customer Metering Inaccuracies			
					Unauthorized Consumption			
					Systematic Data Handling Errors			
				Real Losses	Leakage on Transmission and Distribution Mains			
					Leakage and Overflows at Utility's Storage Tanks			
Leakage on Service Connections up to the point of Customer Metering								


AWWA/IWA

# Leaking – Example

## Probable Leak



## Normal



- Spring Tank Level
- Summer Tank Level
- Summer Booster Flow

Pumping a lot, using a little.  
Where is all the water going?

# Leaking – Example

## Before



## After




# Leaking – Diagnosis



## How to detect:

- Water production exceeds water use
- Pumping, but no demand
- Leak detection equipment
- You see it!




## How to resolve:

- Replace leaky pipes
- Fix leaky storage tanks
- Lower the pressure

# Leaking – Where to Focus

- Old pipes
- High pressures
- Hot spots



Leak on 12" main. Photo courtesy of Harold Hargaves, City of Pocatello, ID.

# Leaking – Activity

In Zone 4, there is a serious leak that consumes approximately 100 MG per year. The pressure in the pipe is currently 100 psi. Your energy team has identified this leak as well as recognized that the pressure can be reduced to 60 psi. The pump that serves this zone uses 1,200 kWh/MG.

1a. How much energy (kWh) is currently lost by the leak each year?

$$\frac{100 \text{ MG}}{\text{year}} * \frac{1,200 \text{ kWh}}{\text{MG}} = 120,000 \text{ kWh/year}$$

1b. At \$0.05 per kWh, how much does this leak cost in terms of energy?

$$\frac{120,000 \text{ kWh}}{\text{year}} * \frac{\$0.05}{\text{kWh}} = \$6,000 \text{ year}$$



# Leaking – Activity

2. How much water (MG) can be saved by reducing the pressure to 60 psi? Assume the % water savings = half of the % pressure reduction.

$$\text{Pressure reduction} = 100 \text{ psi} - 60 \text{ psi} = 40 \text{ psi}$$

$$40 \text{ psi} / 100 \text{ psi} = 40\%$$

$$\text{Percent water savings} = 0.5 * 40\% = 20\%$$

$$\text{Water saved} = 20\% * 100 \text{ MG} = 20 \text{ MG}$$

# Leaking – Activity

3a. How much energy (kWh) can be saved by reducing the pressure?

$$\frac{20 \text{ MG}}{\text{year}} * \frac{1,200 \text{ kWh}}{\text{MG}} = 24,000 \text{ kWh/year}$$

3b. At \$0.05 per kWh, how much money would this save?

$$\frac{24,000 \text{ kWh}}{\text{year}} * \frac{\$0.05}{\text{kWh}} = \$1,200$$


4a. If the leak can be repaired (new pipe), how much energy can be saved?

$$\frac{100 \text{ MG}}{\text{year}} * \frac{1,200 \text{ kWh}}{\text{MG}} = 120,000 \text{ kWh/year}$$

4b. At \$0.05 per kWh, how much would this repair save?


$$\frac{120,000 \text{ kWh}}{\text{year}} * \frac{\$0.05}{\text{kWh}} = \$6,000/\text{year}$$

# LOSING




# Losing – Problem


“Breaking pressure prematurely”



# Losing – Solution




# Losing – Example





# Losing – Example




# Losing – Diagnosis



## How to detect:


- A water source's head is higher than a pumped zone
- Hydraulic modeling




## How to resolve:

- Bypass pressure break and serve zone directly
- Maintain booster backup if needed

# Losing – Activity



# Losing – Activity




$$\frac{60 \text{ MG}}{\text{year}} * \frac{500 \text{ kWh}}{\text{MG}} = 30,000 \frac{\text{kWh}}{\text{year}}$$

$$30,000 \frac{\text{kWh}}{\text{year}} * \frac{\$0.05}{\text{kWh}} = \underline{\$1,500 \text{ year}}$$

1. How much energy (kWh) is currently consumed by flowing to Zone 1 and boosting to Zone 2 to meet demands?
2. At \$0.05 per kWh, what is the energy cost to flow to Zone 1 and boost to Zone 2?

# Losing – Activity



$$\frac{60 \text{ MG}}{\text{year}} * \frac{500 \text{ kWh}}{\text{MG}} = 30,000 \frac{\text{kWh}}{\text{year}}$$

$$30,000 \frac{\text{kWh}}{\text{year}} * \frac{\$0.05}{\text{kWh}} = \underline{\$1,500 \text{ year}}$$

3a. How much energy (kWh) can be saved by fixing the valve and supplying the appropriate amounts to each zone without using the booster pump?


3b. At \$0.05 per kWh, how much money would this adjustment save?

BREAK







# LOADING





# Loading



# Loading





# Tank Utilization




Tanks are batteries! Use storage to meet peak demand

# Loading – Example



# Loading






# Loading



## How to detect:


- Intermittent pump operation (short run, high flow)
- Oversized pumping facilities
- Little storage fluctuation
- Hydraulic modeling




## How to resolve:

- Use equalization storage
- Modify tank setpoints
- Keep source and pump flow as constant as possible
- Modify pump station


# TREASURE HUNTS



# Treasure Hunt Overview



# Conducting a Treasure Hunt



# Preparation

- ☐ Identify focus areas based on energy map and facility knowledge.

- ☐ Who?
- ☐ When?
- ☐ Where?

- ☐ Identify relevant facility staff
- ☐ SEM Coach – facilitator and technical support

- ☐ Prepare energy map
- ☐ Collect and analyze facility information, as needed

- ☐ Select date
- ☐ Reserve conference room
- ☐ Order food

- ☐ Communicate agenda, goals and expectations
- ☐ Ensure staff availability

# Treasure Hunt



Executive  
Sponsor  
Introduction



Facility and  
Energy  
Overview



Opportunity  
Brainstorm



Hunt!



Opportunity  
Sharing



General  
Prioritization (Value  
Graph)



Top 5  
Planning




Closing: Report  
to Executive  
Sponsor




# Ensuring a Successful Treasure Hunt



# Energy value graph



# After the Treasure Hunt



# Good Project management

## Identify

- Project name
- Description
- Location
- System

## Prioritize

- Energy savings
- Cost/effort required
- Decision to implement


## Implement


- Assigned to
- Required action
- Status
- Important dates

## Ensure Persistence

- Risk of backsliding
- Persistence strategy

# TREASURE HUNT ACTIVITY







# Buenaventura Water System







- Source Selection
- Unaccounted Water (Leaking)
- Wholesale Water Use
- Zone 6 Boosting (Losing)



# Unaccounted Water Reduction

- Total Water Production: 6,300 MG
  - Unaccounted Water: 1,575 MG
  - Delivered Water: 4,725 MG
- It is not reasonable to eliminate all unaccounted water losses:
  - Target an unaccounted water percentage of 15% through leak reduction
  - New production target: 5,670 MG
  - Monthly production reduction: 52.5 MG

# Source Selection - Water Supply by Source

- Total Produced: 6,300 MG
  - Wellfield: 3,798 MG
  - Wholesale Purchase: 1,227 MG
  - Treatment Plant: 1,081 MG
  - Deep Well: 194 MG

# Wellfield Energy Intensity

## Wellfield Energy Intensity Comparison

	Power	Power	Flow	Flow	Energy
	kW	Factor	gpm	MGD	Intensity
Well		%			kWh/MG
1	64.7	89.6%	1477	2.1	730
2	37.7	87.4%	1040	1.5	604
3	47.1	83.0%	1310	1.9	599
4	64.0	90.3%	1197	1.7	891
5	74.4	92.2%	1960	2.8	633
6	70.8	90.6%	2420	3.5	488

Energy Used: 2,621,279 kWh

Energy Intensity: 690 kWh/MG

Water Produced: 3,798 MG




# Energy Intensity of Wholesale Water

- Total Purchased Water Taken: 1,227 MG
- Zone 3:
  - Water taken and boosted to primary reservoir: 905 MG
  - Energy to boost water: 760,001 kWh
  - Energy Intensity: 840 kWh/MG
- Zone 2:
  - Water gravity fed: 322 MG
  - Energy to gravity feed: 0 kWh
  - Energy Intensity: 0 kWh/MG

# Wholesale Water Purchase

- Total Purchased Water: 2,200 MG/year
- Water Taken by City: 1,227 MG
  - 55.8% of purchased water
- What are some reasons for using less than purchased?
- Target: 90% of purchased water
  - 1,980 MG

But are we missing something?



# Water Demand by Zone

Total Annual Water Use (Including Unaccounted Water)	6,300	MG
Zone 1	630	MG
Zone 2	1890	MG
Zone 3	1575	MG
Zone 4	945	MG
Zone 5	630	MG
Zone 6 and Higher	315	MG

- Can all the wholesale water be used in Zone 3 or lower?
- Target: 90% of purchased water
  - 1,980 MG
  - Energy intensity: 0 kWh/MG

# Energy Intensity of the Water Treatment Plant

- Energy Used: 1,101,599 kWh
- Water Produced: 1,081 MG
- Energy Intensity: 1,019 kWh/MG
- Oct – Mar Energy Use: 57,700 kWh
- Assumed Baseload: 692,400 kWh
- Production Energy Used: 409,199 kWh
- Production Energy Intensity:  
379 kWh/MG

	Treatment Plant	
	kWh	MG
January	59,100	0.0
February	59,400	0.0
March	47,400	0.0
April	43,800	7.7
May	60,600	108.2
June	132,300	224.8
July	170,100	288.8
August	173,100	304.7
September	175,500	146.5
October	64,499	0.0
November	50,400	0.0
December	65,400	0.0
<b>Total</b>	<b>1,101,599</b>	<b>1,081</b>

# Energy Intensity of the Deep Well

- Energy Used: 512,840 kWh
- Water Produced: 195 MG
- Energy Intensity: 2,624 kWh/MG

# Non-Production Energy Use

- Total Energy Use: 5,475,778 kWh
  - Wellfield Energy: 2,621,279 kWh
  - Deep Well Energy: 512,840 kWh
  - Treatment Plant Energy: 1,101,599 kWh
  - Wholesale Water Energy: 760,001
- Production Energy Use: 4,995,719 kWh
- Non-Production Energy Use: 480,059 kWh
  - What is the energy?
  - Can it be reduced?

# Energy Intensity Summary

- Non-Production Energy Use: 480,059 kWh
- Treatment Plant Fixed Energy Use: 692,400 kWh
- Water Sources:
  - Wellfield:
    - Well 1: 730 kWh/MG
    - Well 2: 604 kWh/MG
    - Well 3: 599 kWh/MG
    - Well 4: 891 kWh/MG
    - Well 5: 633 kWh/MG
    - Well 6: 488 kWh/MG
  - Treatment Plant (variable): 379 kWh/MG
  - Deep Well: 2,624 kWh/MG
  - Wholesale: 0 kWh/MG



# Buenaventura Water System

- Annual Energy Use: 5,475,778 kWh
- Annual Production: 6,300 MG
- Annual Energy Intensity: 793 kWh/MG
- Production Capacity
  - WTP: 216 MGM (May – Sep)
  - Wholesale: 1,980 MGY
  - Deep Well: 25 MGM
  - Wellfield:
    - Well 1: 64 MGM
    - Well 2: 45 MGM
    - Well 3: 57 MGM
    - Well 4: 52 MGM
    - Well 5: 85 MGM
    - Well 6: 104 MGM

# New Buenaventura Strategy

Only  
May – Sep

		WTP	DW	#1	#2	#3	#4	#5	#6	Wholesale
Capacity (MGM)		216	25	64	45	57	52	85	104	1980/yr
Intensity (kWh/MG)		379	2,624	730	604	599	891	633	488	0
Demand (MGM)										
Jan	358									
Feb	312									
Mar	374									
Apr	333									
May	539									
Jun	669									
Jul	805									
Aug	752									
Sep	543									
Oct	385									
Nov	291									
Dec	311									

# New Buenaventura Strategy

		WTP	DW	#1	#2	#3	#4	#5	#6	Wholesale
Capacity (MGM)		216	25	64	45	57	52	85	104	1980/yr
Intensity (kWh/MG)		379	2,624	730	604	599	891	633	488	0
Demand (MGM)										
Jan	358	0								
Feb	312	0								
Mar	374	0								
Apr	333	0								
May	539	216								
Jun	669	216								
Jul	805	216								
Aug	752	216								
Sep	543	216								
Oct	385	0								
Nov	291	0								
Dec	311	0								

409,320

# New Buenaventura Strategy

		WTP	DW	#1	#2	#3	#4	#5	#6	Wholesale
Capacity (MGM)		216	25	64	45	57	52	85	104	1980/yr
Intensity (kWh/MG)		379	2,624	730	604	599	891	633	488	0
Demand (MGM)										
Jan	358	0							104	
Feb	312	0							104	
Mar	374	0							104	
Apr	333	0							104	
May	539	216							104	
Jun	669	216							104	
Jul	805	216							104	
Aug	752	216							104	
Sep	543	216							104	
Oct	385	0							104	
Nov	291	0							104	
Dec	311	0							104	

# New Buenaventura Strategy

		WTP	DW	#1	#2	#3	#4	#5	#6	Wholesale
Capacity (MGM)		216	25	64	45	57	52	85	104	1980/yr
Intensity (kWh/MG)		379	2,624	730	604	599	891	633	488	0
Demand (MGM)										
Jan	358	0				57			104	
Feb	312	0				57			104	
Mar	374	0				57			104	
Apr	333	0				57			104	
May	539	216				57			104	
Jun	669	216				57			104	
Jul	805	216				57			104	
Aug	752	216				57			104	
Sep	543	216				57			104	
Oct	385	0				57			104	
Nov	291	0				57			104	
Dec	311	0				57			104	

409,320

409,716

609,024

# New Buenaventura Strategy

		WTP	DW	#1	#2	#3	#4	#5	#6	Wholesale
Capacity (MGM)		216	25	64	45	57	52	85	104	1980/yr
Intensity (kWh/MG)		379	2,624	730	604	599	891	633	488	0
Demand (MGM)										
Jan	358	0			45	57			104	
Feb	312	0			45	57			104	
Mar	374	0			45	57			104	
Apr	333	0			45	57			104	
May	539	216			45	57			104	
Jun	669	216			45	57			104	
Jul	805	216			45	57			104	
Aug	752	216			45	57			104	
Sep	543	216			45	57			104	
Oct	385	0			45	57			104	
Nov	291	0			45	57			104	
Dec	311	0			45	57			104	

409,320

409,716  
326,160

609,024

# New Buenaventura Strategy

		WTP	DW	#1	#2	#3	#4	#5	#6	Wholesale
Capacity (MGM)		216	25	64	45	57	52	85	104	1980/yr
Intensity (kWh/MG)		379	2,624	730	604	599	891	633	488	0
Demand (MGM)										
Jan	358	0			45	57			104	
Feb	312	0			45	57			104	
Mar	374	0			45	57			104	
Apr	333	0			45	57			104	
May	539	216			45	57			104	
Jun	669	216			45	57			104	
Jul	805	216			45	57		85	104	
Aug	752	216			45	57		55	104	
Sep	543	216			45	57			104	
Oct	385	0			45	57			104	
Nov	291	0			45	57			104	
Dec	311	0			45	57			104	

409,320

409,716

609,024

326,160

88,620

# New Buenaventura Strategy

		WTP	DW	#1	#2	#3	#4	#5	#6	Wholesale
Capacity (MGM)		216	25	64	45	57	52	85	104	1980/yr
Intensity (kWh/MG)		379	2,624	730	604	599	891	633	488	0
Demand (MGM)										
Jan	358	0			45	57			104	152
Feb	312	0			45	57			104	106
Mar	374	0			45	57			104	168
Apr	333	0			45	57			104	127
May	539	216			45	57			104	117
Jun	669	216			45	57			104	247
Jul	805	216			45	57		85	104	298
Aug	752	216			45	57		55	104	275
Sep	543	216			45	57			104	121
Oct	385	0			45	57			104	179
Nov	291	0			45	57			104	85
Dec	311	0			45	57			104	105
		409,320			409,716			609,024		0
					326,160			88,620		



# Water System Energy Use

Non-Production Energy: 408,059 kWh

WTP Fixed Energy: 692,400 kWh

WTP Variable Energy: 409,320 kWh

Well #2: 326,160 kWh

Well #3: 409,716 kWh

Well #5: 88,620 kWh

Well #6: 609,024 kWh

Wholesale Water: 0 kWh

---

**Total: 2,943,299 kWh**

# Energy Savings

Original Strategy: 5,475,778 kWh

Revised Strategy: 2,943,299 kWh

Energy Savings: 2,532,479 kWh


Percent Savings: 46.2%

Original Intensity: 793 kWh/MG

Revised Intensity: 519 kWh/MG

On your smart phone  
Go to: <https://kahoot.it/>  
Game PIN:

**KAHOOT!**



# Takeaways

- Identify leaking, losing, and loading opportunities in your water system
- Keep track of energy saving opportunities
- Start working on energy saving opportunities

# Closing

Questions  
Comments  
Discussion

**SEE YOU TUESDAY!**

**aqua**fficiency®

Saving energy, one gallon at a time