



Pumping System Assessment


Week 4: Finding Data and Examples

Example System for Field Investigation and Analysis



A Flow Control System

Some systems operate continuously but need to have their flow regulated. The flow requirements are dictated by the process, and one would not attempt to maximize the pump efficiency by valve operation. However, operating pump efficiency could be deduced using system measurements. An example process pumping system with a flow control valve is shown below.



Measured data at the pump

Measured Conditions

Water at ambient temperature

P0: 4.3 psig, 7 ft. above floor level; pipe ID = 19.5 inches

P1: 81.2 psig, 12.4 ft above floor level; pipe ID = 12.25 inches

Measured flow rate, using temporary ultrasonic flow meter: 6100 gpm


Motor nameplate data: 2300 volts, 1180 rpm, 80 amps (rated load), 350 hp

Measured current and voltage: 77 amps, 2320 volts


Pump style: End suction

Observed rotational speed: 1190 rpm

Pump operates about 90% of the time; electricity cost is 13 cents/kWhr



Calculate pump head



K_s represents all suction losses from the tank to the pump

K_d represents all discharge losses from the pump to the gauge P_d

Fluid Specific Gravity	<input type="text" value="1"/>		
Flow Rate	<input type="text" value="6100"/>	<input type="text" value="gpm"/>	
Suction		Discharge	
Pipe diameter (ID)	<input type="text" value="19.5"/> in	Pipe diameter (ID)	<input type="text" value="12.25"/> in
Gauge pressure (P_g)	<input type="text" value="4.3"/> psi	Gauge pressure (P_d)	<input type="text" value="81.2"/> psi
Gauge elevation (Z_s)	<input type="text" value="7"/> ft	Gauge elevation (Z_d)	<input type="text" value="12.4"/> ft
Line loss coefficients (K_s)	<input type="text" value="0.5"/>	Line loss coefficients (K_d)	<input type="text" value="1.5"/>

Result Data	
Differential Elevation Head	5.4 ft
Differential Pressure Head	177.7 ft
Differential Velocity Head	3.62 ft
Estimated Suction Friction Head	0.33 ft
Discharge Friction Head	6.43 ft
Pump Head	193.48 ft

Pump head calculation from MEASUR

Evaluate pump operating efficiency

As a first check of the pump operation, the hydraulic and electrical data were plugged into the MEASUR software. The results, shown below, indicate that the pump is very near the optimum commercially available equipment for the noted conditions. MEASUR estimates the pump efficiency to be 87.6%.

Evaluate pump operating efficiency

BASELINE

Operating Hours	<input type="text" value="7884"/>	hrs/yr
Electricity Cost	<input type="text" value="0.13"/>	\$/kWh
Flow Rate	<input type="text" value="6100"/>	gpm
Head	<input type="text" value="193"/>	ft
Calculate Head	<input type="button" value="Calculate Head"/>	
Load Estimation Method	<input type="text" value="Current"/> ▼	
Motor Current	<input type="text" value="77"/>	A
Measured Voltage	<input type="text" value="2320"/>	V

OPTIMAL PUMP

Operating Hours	<input type="text" value="7884"/>	hrs/yr
Electricity Cost	<input type="text" value="0.13"/>	\$/kWh
Flow Rate	<input type="text" value="6100"/>	gpm
Head	<input type="text" value="193"/>	ft
Calculate Head	<input type="button" value="Calculate Head"/>	
Implementation Costs	<input type="text"/>	\$

Evaluate pump operating efficiency


BASELINE

Pump Type	API Double Suction	▼
Pump Speed	1190	rpm
Drive	Direct Drive	▼
Fluid Type	Water	▼
Fluid Temperature	68	°F
Specific Gravity	1	
Kinematic Viscosity	1	cSt
Stages	- + 1	
Line Frequency	60 Hz	▼
Rated Motor Power	350	hp
Motor RPM	1180	rpm
Efficiency Class	Energy Efficient	▼
Rated Voltage	2300	V
Full-Load Amps	80	A

OPTIMAL PUMP


Pump Efficiency	89.9	%
Optimize Pump		
The efficiency of your pump has been calculated based on your system setup. Either directly modify your efficiency or click "Optimize Pump" to estimate your pump efficiency based on a different pump type.		
Pump Speed	1190	rpm
Drive	Specified Efficiency	▼
Drive Efficiency	100	%
Fluid Type	Water	▼
Fluid Temperature	68	°F
Specific Gravity	1	
Kinematic Viscosity	1	cSt
Stages	- + 1	
Line Frequency	60 Hz	▼
Rated Motor Power	350	hp
Motor RPM	1180	rpm
Efficiency Class	Energy Efficient	▼
Rated Voltage	2300	V
Full-Load Amps	80	A
Estimate Full-Load Amps		

Evaluate pump operating efficiency

RESULTS	SANKEY		HELP
	Baseline	Optimal Pump	
Percent Savings (%)	—	—	 3.0%
Pump efficiency (%)	87.6	89.9	
Motor rated power (hp)	350	350	
Motor shaft power (hp)	339.2	330.6	
Pump shaft power (hp)	339.2	330.6	
Motor efficiency (%)	95.6	95.6	
Motor power factor (%)	85.6	84.2	
Percent Loaded (%)	97	94	
Drive efficiency (%)	100	100	
Motor current (amps)	77	76	
Motor power (kW)	264.7	258	
Annual Energy (MWh)	2,087	2,034	
Annual Energy Savings (MWh)	—	53	
Annual Cost	\$271,327	\$264,429	
Annual Savings	—	\$6,899	

Check the manufacturer's data


To provide an independent check on the measured data, the manufacturer's pump performance curves, adjusted for the observed speed (using the pump affinity laws) were consulted. The head-capacity curve is shown below.



Pump head-capacity curve

Check the manufacturer's data

The efficiency-capacity curve is shown below.



A happy pump!

The calculated head and flow rate match the manufacturer's curve; furthermore, the MEASUR-estimated efficiency is consistent with the manufacturer's curve.

In summary, the observed measurements and subsequent analysis suggests that the pump:


- is operating very near its BEP (best efficiency point)
- is operating consistent with the manufacturer's performance curves, indicating minimal wear along with the motor, is operating near the PSAT-calculated optimal condition (note that the Optimization Rating is 97.4).

The Optimization Rating is a measure of the combined motor and pump performance relative to the optimal commercially available equipment, expressed as a percentage (equivalent to a grade on an exam).

As will be shown, these observations, while true, are very misleading. They apply to the motor and pump *only*.

Moving downstream a little we find.....


As noted above, the pump and motor are operating very efficiently, as judged by the head and flow rate output compared with the electrical power input. But it should always be the goal to judge how well the system as a whole is functioning, not just the individual components. Below, a slightly broadened view of the system is shown. A portion of the flow handled by the pump is diverted and recirculated back to the suction tank. This recirculated flow represents wasted energy.



Process system, including recirculation line


The recirculation line control valve

Flow rate was not measured in the recirculation line, but valve V2 position was noted to be full open. A picture of a valve similar to the recirculation valve, and valve flow coefficient vs. position are shown below.



Pumping 2940 gpm around in a circle!

Using the valve performance data, pipe and component geometric data, and measured pressures, the flow rate through the recirculation line was estimated to be 2940 gpm. Thus, the net flow rate is 3160 gpm. The flow distributions are illustrated below.



Process system flow distribution

Could use Valve Tool to estimate flow

Valve head and energy calcs 2008

File


Units: **gpm, ft, inches, psig**

Available data selector: **Flow rate from delta-P, Cv**

Operating fraction: 0.900
Average electrical cost rate, \$/kWh: 0.1300
Pump efficiency, %: 87.9
Motor efficiency, %: 95.0

Head loss, ft: 142.07
Frictional power loss, hp: 105.5
Frictional electrical power, kW: 94.2
Annual cost of friction, \$: 96553

Specific gravity: 1.000
Calculated flow rate: 2940



Specified valve Cv: 375.0

Upstream pressure, psig: 65.5
Downstream pressure, psig: 4.0
Upstream pipe ID, inches: 6.00
Valve size, inches: 6.00
Downstream pipe ID, inches: 6.00
Upstream gauge elev, ft: 5.0
Downstream gauge elev, ft: 5.0
Upstream gauge velocity, ft/s: 33.4
Valve velocity, ft/s: 33.4
Downstream gauge velocity, ft/s: 33.4

0.000 K_reducer & expander
8.21 K_valve
8.21 K_total

Create new log Retrieve log entry

Application and Copyright notice

STOP

Gaining A System Perspective

Recognizing that only a little more than half the pump flow rate (3160 gpm) is going to the intended target, a revised MEASUR analysis can be performed using this net flow value. The result is shown below.

MEASUR analysis continued,

BASELINE

Operating Hours	<input type="text" value="7884"/>	hrs/yr
Electricity Cost	<input type="text" value="0.13"/>	\$/kWh
Flow Rate	<input type="text" value="6100"/>	gpm
Head	<input type="text" value="193"/>	ft
Calculate Head	Calculate Head	
Load Estimation Method	<input type="text" value="Current"/>	▼
Motor Current	<input type="text" value="77"/>	A
Measured Voltage	<input type="text" value="2320"/>	V

USEFUL FLOW IS 3160 GPM

Operating Hours	<input type="text" value="7884"/>	hrs/yr
Electricity Cost	<input type="text" value="0.13"/>	\$/kWh
Flow Rate	<input type="text" value="3160"/>	gpm
Head	<input type="text" value="193"/>	ft
Calculate Head	Calculate Head	
Implementation Costs	<input type="text"/>	\$

MEASUR analysis

BASELINE	
Pump Type	API Double Suction
Pump Speed	1190 rpm
Drive	Direct Drive
Fluid Type	Water
Fluid Temperature	68 °F
Specific Gravity	1
Kinematic Viscosity	1 cSt
Stages	- + 1
Line Frequency	60 Hz
Rated Motor Power	350 hp
Motor RPM	1180 rpm
Efficiency Class	Energy Efficient
Rated Voltage	2300 V
Full-Load Amps	80 A

USEFUL FLOW IS 3160 GPM


Pump Efficiency	45.3906 %
Optimize Pump	
The efficiency of your pump has been calculated based on your system setup. Either directly modify your efficiency or click "Optimize Pump" to estimate your pump efficiency based on a different pump type.	
Pump Speed	1190 rpm
Drive	Specified Efficiency
Drive Efficiency	100 %
Fluid Type	Water
Fluid Temperature	68 °F
Specific Gravity	1
Kinematic Viscosity	1 cSt
Stages	- + 1
Line Frequency	60 Hz
Rated Motor Power	350 hp
Motor RPM	1180 rpm
Efficiency Class	Energy Efficient
Rated Voltage	2300 V
Full-Load Amps	80 A

[Estimate Full-Load Amps](#)

Gaining A System Perspective

RESULTS	SANKEY	HELP
	Baseline	Useful Flow is 3160 gpm
Percent Savings (%)	— —	
Pump efficiency (%)	87.6	45.4
Motor rated power (hp)	350	350
Motor shaft power (hp)	339.2	339.2
Pump shaft power (hp)	339.2	339.2
Motor efficiency (%)	95.6	95.6
Motor power factor (%)	85.6	84.4
Percent Loaded (%)	97	97
Drive efficiency (%)	100	100
Motor current (amps)	77	78
Motor power (kW)	264.7	264.7
Annual Energy (MWh)	2,087	2,087
Annual Energy Savings (MWh)	—	
Annual Cost	\$271,327	\$271,327
Annual Savings	—	\$00

Optimum pump is 88.5% efficient


RESULTS	SANKEY		HELP
	Baseline	Optimized Pump at 3160 gpm	
Percent Savings (%)	—	 48.0%	
Pump efficiency (%)	87.6	88.5	
Motor rated power (hp)	350	350	
Motor shaft power (hp)	339.2	174	
Pump shaft power (hp)	339.2	174	
Motor efficiency (%)	95.6	94.7	
Motor power factor (%)	85.6	74.9	
Percent Loaded (%)	97	50	
Drive efficiency (%)	100	100	
Motor current (amps)	77	45	
Motor power (kW)	264.7	137	
Annual Energy (MWh)	2,087	1,080	
Annual Energy Savings (MWh)	—	1,007	
Annual Cost	\$271,327	\$140,397	
Annual Savings	—	\$130,930	

Gaining A System Perspective

There is a dramatic effect on the outcome; the Optimization Rating dropped from 97.4 to 51.3. Significantly, the annual cost, estimated to be \$271,300, could be reduced by \$131,000 with a pump selected to deliver the net flow only (i.e., with the bypass or recirculation valve closed).

Going further downstream.....


Expanding the view to include the entire system shows that the flow rate to the receiver, or discharge tank, is controlled by another valve, V1, whose position is controlled by a signal from an in-line magnetic flow meter.



Complete process system diagram

There is this pinched flow control valve

A picture of the flow meter and control valve is provided below.



Using the valve equation

Based on the calculated valve flow coefficient of 476 from the valve indicator and valve flow coefficient plot, the pressure drop across the control valve can be estimated. The fundamental equation relating the valve flow coefficient, flow rate, and pressure drop is:

$$Q = C_v \sqrt{\frac{\Delta P}{\text{s.g.}}} \quad \text{or} \quad \Delta P = \frac{\text{s.g.} \times Q^2}{C_v^2} \quad \rightarrow \quad \Delta P = \frac{1.0 \times 3160^2}{476^2} = 44 \text{ psig}$$

where Q is the flow rate in gpm, Cv is the valve flow coefficient, DP is the pressure drop across the valve in psig, and s.g. is the specific gravity. The pressure drop across the valve was actually measured to be 39 psig.

Gaining A System Perspective

The pressure drop across the valve represents head developed by the pump that exceeds that necessary to deliver the required flow rate to the discharge tank. This pressure drop can be subtracted from the pump head to calculate the head actually required. The MEASUR analysis was re-run after subtracting the measured head loss ($39 \text{ psig} * 2.31 \text{ ft/psig} = 90 \text{ ft}$) from the calculated pump head (193.5 ft) previously used.

Downsize pump and motor

BASELINE	
Operating Hours	<input type="text" value="7884"/> hrs/yr
Electricity Cost	<input type="text" value="0.13"/> \$/kWh
Flow Rate	<input type="text" value="6100"/> gpm
Head	<input type="text" value="193"/> ft
Calculate Head	
Load Estimation Method	<input type="text" value="Current"/> ▼
Motor Current	<input type="text" value="77"/> A
Measured Voltage	<input type="text" value="2320"/> V


OPTIMIZED PUMP AT 3160 GPM @ 103 FT	
Operating Hours	<input type="text" value="7884"/> hrs/yr
Electricity Cost	<input type="text" value="0.13"/> \$/kWh
Flow Rate	<input type="text" value="3160"/> gpm
Head	<input type="text" value="103"/> ft
Calculate Head	
Implementation Costs	<input type="text" value=""/> \$

Downsize pump and motor

BASELINE	
Pump Type	API Double Suction
Pump Speed	1190 rpm
Drive	Direct Drive
Fluid Type	Water
Fluid Temperature	68 °F
Specific Gravity	1
Kinematic Viscosity	1 cSt
Stages	- + 1
Line Frequency	60 Hz
Rated Motor Power	350 hp
Motor RPM	1180 rpm
Efficiency Class	Energy Efficient
Rated Voltage	2300 V
Full-Load Amps	80 A

OPTIMIZED PUMP AT 3160 GPM @ 103 FT	
Pump Efficiency	88.5 %
Optimize Pump	
The efficiency of your pump has been calculated based on your system setup. Either directly modify your efficiency or click "Optimize Pump" to estimate your pump efficiency based on a different pump type.	
Pump Speed	1190 rpm
Drive	Specified Efficiency
Drive Efficiency	100 %
Fluid Type	Water
Fluid Temperature	68 °F
Specific Gravity	1
Kinematic Viscosity	1 cSt
Stages	- + 1
Line Frequency	60 Hz
Rated Motor Power	100 hp
Motor RPM	1180 rpm
Efficiency Class	Energy Efficient
Rated Voltage	2300 V
Full-Load Amps	23.79 A
Estimate Full-Load Amps	

Downsize pump and motor

RESULTS	SANKEY		HELP
	Baseline	Optimized Pump at 3160 gpm @ 103 ft	
Percent Savings (%)	—	 72.0%	
Pump efficiency (%)	87.6	88.5	
Motor rated power (hp)	350	100	
Motor shaft power (hp)	339.2	92.8	
Pump shaft power (hp)	339.2	92.8	
Motor efficiency (%)	95.6	94.8	
Motor power factor (%)	85.6	82.7	
Percent Loaded (%)	97	93	
Drive efficiency (%)	100	100	
Motor current (amps)	77	22	
Motor power (kW)	264.7	73.1	
Annual Energy (MWh)	2,087	576	
Annual Energy Savings (MWh)	—	1,511	
Annual Cost	\$271,327	\$74,888	
Annual Savings	—	\$196,439	

Gaining A System Perspective

Thus, when viewed from a component perspective, the pump and motor operate very efficiently; however, when viewed from a system perspective, the pump is significantly oversized for the job at hand. Note that in the MEASUR analysis, the optimal pump could be powered by a 100 hp motor instead of the 350 hp motor required for the existing pump. Also note that the annual energy cost could be reduced by almost \$200,000 if the optimal pump and motor were employed.

Concluding Remarks

This article has demonstrated two important perspectives related to valve control of pumping systems:



Throttling valves to achieve improved pump efficiency in systems whose function is to deliver a given volume is almost never a good idea,

Efficient pump and/or motor operation is decidedly not an indication of effective or efficient system operation.

Cavitation

Water Boils at:

- 212 F when the pressure is 14.70 psia
- 203 F when the pressure is 12.27 psia
- 60 F when the pressure is 0.26 psia
- 250 F when the pressure is 28.84 psia



Net Positive Suction Head


Net Positive Suction Head

$NPSHA = \text{Total suction head (absolute)} - \text{fluid vapor pressure (absolute)}$

$$NPSHA = \frac{V_s^2}{2g} + \frac{2.31(P_s + P_a)}{s.g.} + Z_s - \frac{2.31P_v}{s.g.}$$

$$NPSHA = \frac{V_s^2}{2g} + \frac{2.31(P_s + P_a - P_v)}{s.g.} + Z_s$$


- V_s = pump suction velocity (ft/s)
- P_s = suction gauge pressure (psig)
- P_a = atmospheric pressure (psia)
- P_v = fluid vapor pressure (psia)
- g = gravitational constant (32.174 ft/s²)
- s.g. = fluid specific gravity (dimensionless)
- Z_s = suction gauge elevation above pump suction datum (ft)




Net Positive Suction Head Required

- NPSHR is, by long-term accepted practice, the available suction head at which the developed pump head has dropped by 3% from the head that it produced with bountiful available suction head
- By definition, then, the pump performance is already degraded due to cavitation-related flow disturbance
- The actual point when cavitation actually begins can be with significantly greater available head than the pump supplier's NPSHR curve
- Two accepted approaches for developing the NPSHR curve:
 - Establish a fixed suction head, then increase flow rate until a 3% reduction in head at a particular flow rate is observed
 - Maintain a constant flow rate and gradually decrease the suction head until the developed head drops by 3%

NPSHR: Available suction head with 3% degradation in developed head




Finish water pump layout



NPSHR Curve for pump on previous slide

At what flow rate would NPSHR exceed NPSHA?
(Assume $P_s = 14.7$ psia and water temperature = 60 degrees F)



Calculate NPSHA


Water saturation vapor pressure at 60 F= 0.26 psia

Reference location for suction head determination is the water surface

$$\text{NPSHA} = \frac{V_s^2}{2g} + \frac{2.31 (P_s + P_a - P_v)}{\text{s.g.}} + Z_s$$


$$\text{NPSHA} = \frac{0^2}{64.352} + \frac{2.31 (0 + 14.7 - 0.26)}{1.00} + 10.5 = \boxed{43.9 \text{ ft}}$$

Answer: NPSHR would exceed NPSHA at just over 2500 gpm



Actual Pump Data for VSD Operation

Variable Speed Pumping




Parallel Pumping Example 1



5 of 8 Pumps
Operate in Parallel


Parallel Pumping Example

Parallel Pumps



Parallel Pumping Example

Parallel Pumps



With 2-pumps, each produces 2,600 gpm, 5,200 gpm total; With 5-pumps, the 5th pump increases flow by 1,100 gpm, from 8,900 to 10,000 gpm

Parallel Pumping Example

- Production only requires 4 pumps – the 5th is insurance in case one pump fails
- The opportunity is to add automatic start up controls and operate 4 pumps instead of 5
- Operating 5 pumps produces 1100 gpm of additional flow and pump head increases from 78 feet to 92 feet
- Pump efficiency is 70% and the cost of electricity is \$0.08/kWh, saves 63.9 kW

Savings:

$$\text{kW}_{\text{init}} = (10000 \text{ gpm} \times 92 \text{ feet} \times 0.746) / (3960 \times 0.7 \times 0.95) = 260.6 \text{ kW}$$

$$\text{kW}_{\text{final}} = (8900 \text{ gpm} \times 78 \text{ feet} \times 0.746) / (3960 \times 0.7 \times 0.95) = 196.7 \text{ kW}$$

$$\text{\$ Saved} = (260.6 - 196.7) \text{ kW} \times 8760 \text{ hr/yr} \times 0.08 \text{ \$/kWh} = \$44,781/\text{yr}$$

$$\text{Estimated project cost} = \$30,000$$

$$\text{Payback} = \$30,000 / \$44,781 = 0.7 \text{ years}$$

Parallel Pumping Example 2




Parallel Pumping Example 2

- A coolant circulating system has five 100 HP vertical turbine pumps
- Three of the five are operated 24/7
- Many of the machining processes shut down over night
- The header pressure was logged over night and from 11 pm until 5 am the pressure was a flat 96 psig
- The typical pressure during the rest of the day is 65 psig
- The plan agreed with by the plant engineers was to turn off one pump for 6 hours/day

Parallel Pumps: Header Pressure

V8 B2 Coolant Header Pressure North Side



Parallel Pumping Example 2

Savings

$$\text{kW} = 100 \text{ HP} \times 0.6 \text{ loaded} \times 0.746 = 44.8 \text{ kW}$$

$$\text{Pump down time} = 6 \text{ hr/day} \times 360 \text{ days/yr} = 2160 \text{ hr/yr}$$

$$\text{Cost savings} = 44.8 \text{ kW} \times 2160 \text{ hr/yr} \times 0.08 \text{ \$/kWh} = \$7,741/\text{yr}$$

The pump will be manually started/stopped

Project cost = \$0


Payback = Immediate

Parallel Pumping Example 3

- Juruti Bauxite Mine
- Have 3 – 800 HP wash pump in parallel
- 2 pumps normally operate
- Pumps are oversized
- 50 meters of head is dropped across the control valves
- Electricity costs \$0.265/kWh
- Recommended replacing one pump with one correctly sized



New Pump Operation



— System Curve
 — Parallel Pumps: 100% Speed
 — Pump at 100% Speed
 — New Pump
 — New System Curve

	Condition A	Condition B	
Pump, fluid	API double suction	API double suction	
	Pump rpm: 1790	Pump rpm: 1790	
	Drive: Direct drive	Drive: Direct drive	
	Units: m ³ /hr, m, kW	Units: m ³ /hr, m, kW	
	Kinematic viscosity (cS): 1.00	Kinematic viscosity (cS): 1.00	
	Specific gravity: 1.000	Specific gravity: 1.000	
	# stages: 1	# stages: 1	
	Fixed specific speed? YES	Fixed specific speed? YES	
	Line freq: 60 Hz	Line freq: 60 Hz	
	1160.0 kW <<Spec	580.0 kW <<Spec	
Motor	Motor rpm: 1787	Motor rpm: 1787	
	Eff. class: Average	Eff. class: Average	
	Voltage: 4000	Voltage: 4000	
	Estimate FLA	Estimate FLA	
	Full-load amps: 195.1	Full-load amps: 99.0	
	Size margin, %: 0	Size margin, %: 0	
	Duty, unit cost	Operating fraction: 0.850	Operating fraction: 0.850
		\$/kwhr: 0.2650	\$/kwhr: 0.2650
	Field data	Flow rate, m ³ /h: 2400	Flow rate, m ³ /h: 2400
		Head tool: Head, m: 122	Head tool: Head, m: 72.0
Load estim. method: Power		Load estim. method: Power	
Motor kW: 1180.0		Motor kW: 561.0	
	Voltage: 4060	Voltage: 4060	
	Retrieve defaults	Set defaults	
	Copy A > to B >	Copy B < to A <	
	System curve tool: select below	Background information	
		STOP	

	Condition A			Condition B		
	Existing	Optimal	Units	Existing	Optimal	Units
Pump efficiency	70.4	88.6	%	87.5	88.7	%
Motor rated power	1160	900	kW	580	560	kW
Motor shaft power	1131.8	899.0	kW	537.0	529.7	kW
Pump shaft power	1131.8	899.0	kW	537.0	529.7	kW
Motor efficiency	95.9	96.3	%	95.7	96.2	%
Motor power factor	89.3	88.8	%	87.9	87.6	%
Motor current	187.8	149.6	amps	90.8	89.4	amps
Motor power	1180.0	933.7	kW	561.0	550.9	kW
Annual energy	8765.8	6952.6	MWh	4177.0	4102.0	MWh
Annual cost	2328.4	842.4	\$1000	1107.0	1087.0	\$1000
Annual savings potential, \$1,000		485.9			19.9	
Optimization rating, %		79.1			98.2	

Log file controls:		Summary file controls:	
Create new log	Add to existing log	Create new summary file	
Retrieve log entry	Delete log entry	Existing summary files	
		CREATE NEW	


Documentation section			
Facility	Juruti Mine	System	Washer Supply Pumps
Date	5/18/2001		
Application	Reduce Pumping Capacity	Evaluator	Cunningham
General comments			
Current condition: Operate 2 pumps in parallel. Header pressure is 12.3 kgf/cm ² (175 psig). Expected flow is 2,400 m ³ /hr. Plant header is 9-10.5 kgf/cm ² (145 psig). Pressure reported to be needed is 6 kgf/cm ² (85 psig).			

Condition B Notes:

Savings: \$1,221,400/yr
 4609 MWh

Parallel Pumping Example 3

Possible New Pump




Throttled Pump Example 1

- Condenser Tower Pump #2
- One 100 HP end suction centrifugal pump
- Pump is oversized
- Butterfly valve at discharge is 30% open
- With VFD pump speed can be reduced from 1789 rpm to 1290 rpm and valve opened
- Motor input power falls from 54.9 kW to 24.7 kW
- Saves 241,667 kWh worth \$17,400/year
- Cost \$15,000 Payback 0.9 yrs




Throttled Pump Example 1

Condenser Tower Pump #2



Throttled Pump Example 1



Company: Cunningham Engineering, Inc.
 Name: Condenser Tower #2 Pump
 1/21/2011

AURORA PUMPS
 Catalog: Aurora Pumps 60 Hz, Vert 3-4
 3-4D 1 STD-END SU C - 1800
 Design Point: 2700 US gpm, 75 ft

Size: 8-6-128
 Speed: 1750 rpm
 Dia: 11.1875 in
 Curve: 3FC-187798



Throttled Pump Example 1

Explore Opportunities Modify All Conditions
 Novice View Expert View

Install VFD Open Valve
 Selected Scenario [View / Add Scenarios](#)

SELECT POTENTIAL ADJUSTMENT PROJECTS
 Select potential adjustment projects to explore opportunities to increase efficiency and the effectiveness of your system.

[Add New Scenario](#)


Modification Name:

Install VFD

Baseline	Modifications
Flow Rate 1,771 gpm	Flow Rate <input type="text" value="1771"/> gpm
Head 116 ft	Head <input type="text" value="51"/> ft Calculate Head
Motor Drive Direct Drive	Drive Efficiency <input type="text" value="97"/> %
Pump Type End Suction ANSI/API	Pump Efficiency <input type="text" value="74.1"/> % Optimize Pump

The efficiency of your pump has been calculated based on your system setup. Either directly modify your efficiency or click "Optimize Pump" to estimate your pump efficiency based on a different pump type.

Adjust Operational Data

	RESULTS	SANKEY	HELP
	Baseline	Install VFD Open Valve	
Percent Savings (%)	---	 54.0%	
Pump efficiency (%)	74.1	74.1	
Motor rated power (hp)	100	100	
Motor shaft power (hp)	70.1	31.8	
Pump shaft power (hp)	70.1	30.8	
Motor efficiency (%)	95.1	93.1	
Motor power factor (%)	83.7	66.5	
Percent Loaded (%)	70	32	
Drive efficiency (%)	100	97	
Motor current (A)	83	48	
Motor power (kW)	55	25.5	
Annual CO2 Emissions (tonne CO₂)	189.6	87.7	
Annual CO2 Emissions Savings (tonne CO₂)	---	101.9	
Annual Energy (MWh)	440	204	
Annual Energy Savings (MWh)	---	236	
Annual Cost (\$)	31,685	14,660	
Annual Savings (\$)	---	17,025	

The End for Session 4



The End