



Industrial Steam Systems **Virtual INPLT Training & Assessment**

Session 4

Thursday – October 17, 2024

10 am – 12:30 pm

Welcome

- Welcome to the fourth Steam Virtual INPLT training series
- Eight, 2-1/2 hour webinars, focused on Industrial Steam Systems Energy Assessment and Optimization
- These webinars will help you gain a significant understanding of your industrial steam system, undertake an energy assessment using a systems approach, evaluate and quantify energy and cost-saving opportunities using US DOE tools and resources
- Thank you for your interest!



Steam Virtual INPLT Agenda

- Session 1 (October 2) – Industrial Steam Systems Fundamentals and Introduction to SSST
- Session 2 (October 3) – Focus on Steam System Generation and Introduction to DOE’s MEASUR Tool
- Session 3 (October 16) – Steam System Generation & Cogeneration (CHP)
- **Session 4 (October 17) – Steam System Distribution, End-Use & Condensate Recovery**
- **Session 5 (October 30) – Energy Efficiency Opportunities in the Generation Area**
- **Session 6 (October 31) – Energy Efficiency Opportunities in Cogeneration (CHP) Area**
- **Session 7 (November 13) – EE Opportunities in Distribution, End-use and Condensate Recovery**
- **Session 8 (November 14) – Industrial Steam System VINPLT Wrap-up Presentations**

Agenda – Session FOUR

- Safety and Housekeeping
- Today's Content:
 - Steam System – Distribution, End-Use & Recovery
 - Understanding the steam header system
 - End-Uses of steam and steam balance
 - Steam traps, condensate collection & return
 - US DOE MEASUR Tool
 - Completing the steam system model
 - Better Plants Diagnostic Equipment Program (DEP)
- Kahoot Quiz Game
- Q&A



Safety and Housekeeping

- Safety Moment

- Do not use cell-phones or get distracted while walking in the plant or when working
- Observe areas which are cordoned off temporarily due to ongoing work

- Break points after each sub-section where you can ask questions

- When you are not asking a question, please MUTE your mic and this will provide the best sound quality for all participants

- We will be recording all these webinars and by staying on-line and attending the meeting you are giving your consent to be recorded

- A link to the recorded webinars will be provided, afterwards



Distribution

- Header Pressures
- Letdown Stations
- Header Losses

Example Steam System – Pulp & Paper Mill

- Pressure levels for steam distribution in the plant
 - High pressure – 400 psig
 - Medium pressure – 150 psig
 - Low pressure – 30 psig
- Use a 3-header steam system model
- Steam usage will be determined in the End-Use section for each header

Example Steam System – Pulp & Paper Mill

MEASUR

VINPLT_0421
Last modified: Apr 23, 2021

System Setup Assessment Diagram Report

1 Assessment Settings 2 Operations 3 Boiler 4 Header 5 Turbine

Flash Condensate Return	No	▼
High Pressure Header		
Pressure	400	psig
Process Steam Usage	<input type="text"/>	klb/hr
Value Required		
Condensate Recovery Rate	<input type="text"/>	%
Value Required		
Heat Loss	0	%
Medium Pressure Header		
Pressure	150	psig
Process Steam Usage	<input type="text"/>	klb/hr
Value Required		
Condensate Recovery Rate	<input type="text"/>	%
Value Required		
Flash Condensate Into Header	No	▼
Heat Loss	0.1	%
Desuperheat Steam out of Highest Pressure Header	No	▼
Low Pressure Header		
Pressure	30	psig
Process Steam Usage	<input type="text"/>	klb/hr
Value Required		
Condensate Recovery Rate	<input type="text"/>	%
Value Required		
Flash Condensate Into Header	No	▼
Heat Loss	0.1	%
Desuperheat Steam out of Medium Pressure Header	No	▼

Letdowns / PRVs

- Pressure Reducing Valves (PRVs) are most prevalent method of reducing pressure in a steam system
- A steam system will have one or more PRVs between two headers
- Not all PRVs maybe controlling header pressures
- Steam temperature at the outlet of the PRVs is controlled by feedwater (Desuperheaters)
- Mainly done for
 - Protecting equipment
 - Design conditions
 - Reducing pressure drop

Desuperheat Steam out of Highest Pressure Header

No



Header Heat Loss

- The heat transfer loss associated with the piping distribution system is related to the total enthalpy flow entering the header in question
 - The enthalpy reference datum (h_{datum}) is 0.0 Btu/lbm
 - 32°F and 0 psig
- The loss (non-impact) can be expressed as
 - A fraction (percentage) of the total enthalpy entering the header
- 3E Plus can be utilized to estimate this loss

Header Heat Loss

- The header heat loss impacts the energy delivered to the process units
 - The mass flows to the process demands remain as specified but the energy content of the steam is diminished

Heat Loss	<input type="text" value="0"/>	%
-----------	--------------------------------	---

End-Use

- **Steam Mass Balance**
- **Steam Usage on Different Headers**
- **Significant Steam User**

Process Steam Demand Evaluation

- US DOE MEASUR is a “pull type” model
 - Process steam flows “pull” steam through the boiler
 - Typically modeling activities strive to match general boiler load
- Process steam flows are established by:
 - Direct continuous flow measurement
 - Direct intermittent flow measurement
 - Mass balance
 - Energy balance
 - System or Process design information
 - Empirical standards or data

Flow Measurements

- Steam flow measurement is typically completed by conventional flow meters
 - Orifice plates
 - Vortex
- Condensate flow measurement is often completed by intermittent field observations
 - Timed volume capture
 - Condensate receiver fill and discharge
 - Known volume fill

Mass & Energy Balances

- Conservation of mass principle can often be applied very effectively
- The first law of thermodynamics (energy balance) for heat exchange is typically applied to:
 - Steam alone
 - Heated material alone


$$\dot{Q}_x = \dot{m}_x (C_p)_x (T_e - T_i)_x \quad \left. \vphantom{\dot{Q}_x} \right\} \text{For constant specific heats and when enthalpy is a function of temperature only}$$

$$\dot{Q}_x = \dot{m}_x (h_e - h_i)_x \quad \left. \vphantom{\dot{Q}_x} \right\} \text{When material enthalpies are known}$$

$$\dot{Q}_{steam} = -\dot{Q}_x \quad \left. \vphantom{\dot{Q}_{steam}} \right\} \text{Typical heat exchanger applications}$$

Steam Balance

- Account for significant steam energy users
- Aim to get 80-85% steam usage accounted using some form of steam flow / condensate measurement



End Use	Steam (lb/hr)	Energy (MMBtu)	% of Total (%)
Cooker C	37,983	246,131	26.1
Cooker B	35,684	231,231	24.5
Finisher	33,590	217,663	23.1
Cooker A	22,996	149,013	15.8
Hydrolyzer	4,000	25,920	2.7
Preheater (Cooker A)	4,000	25,920	2.7
East Feather Dryer	1,776	11,508	1.2
West Feather Dryer	1,776	11,508	1.2
Coagulator	1,000	6,480	0.7
Blood Dryer	1,000	6,480	0.7
Hot water exchanger	250	1,620	0.2
Other	1,505	9,753	1.0
Total	145,560	943,229	100.0

} Significant Steam Energy Users

Polling Questions 1-2

Polling Question

1. Will you be able to prepare a list of users which account for 80% of steam in your plant?
 - A. Yes
 - B. No
 - C. Don't know

2. Will you be able to measure the steam used by these major users?
 - A. Yes
 - B. No
 - C. Don't know

Example Steam System – Pulp & Paper Mill

- Steam usage at different pressure levels for steam distribution in the plant
 - High pressure – 400 psig – 8 klb/hr
 - Medium pressure – 150 psig – 30 klb/hr (Significant energy user – Digester)
 - Low pressure – 30 psig – 50 klb/hr (Significant energy users – Paper Machines, Driers)
- Use a 3-header steam system model

Medium Pressure Header

Pressure

150

psig

Process Steam Usage

30

klb/hr


Condensate Recovery

- Steam Traps
- Condensate Collection System
- Flash Tanks
- Condensate Return


Steam Traps

- Thermostatic
- Closed Float
- Float and Thermostatic
- Open Float
- Thermodynamic
- Orifice

Thermostatic Steam Traps




Thermostatic Steam Traps




Thermostatic Steam Traps


- Opens to subcooled condensate
- Can discharge condensate or condensate and flash steam depending on subcooling
- Allows energy recovery from condensate
- Significant air-removal capability



Closed Float Steam Trap




Closed Float Steam Trap




Closed Float Steam Trap


- Rarely applied in this form in steam systems
- Opens to saturated condensate
- Will discharge condensate and flash steam
- Poor (no) air-removal capability



Float and Thermostatic Steam Trap




Float and Thermostatic Steam Trap




Float and Thermostatic Steam Trap


- Opens to saturated condensate
- Will discharge condensate and flash steam
- Significant air-removal and startup capabilities
- Modulating type operation



Open Float (Inverted Bucket) Steam Trap




Open Float (Inverted Bucket) Steam Trap




Open Float (Inverted Bucket) Steam Trap


- Opens to saturated condensate
- Will discharge condensate and flash steam
- Limited air-removal capability
- Application in superheated steam service should be investigated
- Intermittent operation



Thermodynamic Steam Traps




Thermodynamic Steam Traps




Thermodynamic Steam Traps


- Opens to saturated condensate
- Will discharge condensate and flash steam
- Intermittent operation
- Can be equipped with thermostatic element to improve air removal



Orifice Steam Traps




Orifice Steam Traps



Orifice Steam Traps

- No moving parts
- Continuous operation
- Common applications are steady loads
- Limited air-removal capability due to orifice limitations



Process Condensate

- MEASUR condensate receiver operates at atmospheric pressure
- MEASUR condensate return temperature provides an indication of the energy loss associated with the condensate return system
 - MEASUR condensate exits a process heat exchanger as a saturated liquid at the pressure of the heat exchanger

Condensate Return

Condensate Return Temperature

150 °F

Flash Condensate Return

No

Process Condensate


- Condensate recovery percentage describes the amount of process steam recovered in the condensate system
- Flash steam recovery systems allow recovered condensate to flash steam into lower-pressure steam systems
- Makeup water temperature impacts condensate related projects

Medium Pressure Header

Pressure	150	psig
Process Steam Usage	30	klb/hr
Condensate Recovery Rate	50	%
Flash Condensate Into Header	No	▼

Condensate Recovery / Flash Steam

- Condensate is saturated liquid at the header pressure
 - Some sub-cooling may occur depending on heat losses, heat exchanger design, process conditions, etc.
- This condensate has a lot of energy and can be flashed to produce steam for lower pressures




	Inlet	Steam Out	Liquid Out
Pressure (psig)	400	150	150
Temperature (°F)	448.2	365.9	365.9
Sp. Enthalpy (Btu/lb)	428.2	1,196	338.6
Sp. Entropy (Btu/lb-°F)	0.626	1.562	0.524
Quality	Liquid	Gas	Liquid
Mass Flow (klb/hr)	10	1.04	8.96
Energy Flow (MMBtu/hr)	4.3	1.2	3

US DOE MEASUR

- **Building a Steam System Model**

MEASUR – Pulp & Paper Mill Model



MEASUR – Pulp & Paper Mill Model

COST SUMMARY

Power Balance	
Generation	0 kW
Demand	5,000 kW
Import	5,000 kW
Unit Cost	\$0.05 /kWh
Total \$/yr	\$2,190,000

Fuel Balance	
Boiler	147.02 MMBtu/hr
Unit Cost	\$5.00 /MMBtu
Total \$/yr	\$6,439,310

Make-Up Water	
Flow	100.64 gpm 52,898,985.56 gal
Unit Cost	\$0.01 /gal
Total \$/yr	\$528,990

Total Operating Cost	
	\$9,158,299

Marginal Steam Costs

- Marginal steam costs are typically used when analyzing
 - Steam leaks
 - Process changes
 - Elimination or institution of nominal steam use
- Marginal steam costs are impacted by condensate return
 - Amount
 - Temperature

MARGINAL STEAM COST	
High Pressure	\$9.04 /klb
Medium Pressure	\$9.04 /klb
Low Pressure	\$9.04 /klb

Low-pressure Header Vent

- The low-pressure header can operate in an “unbalanced” state
 - This can develop in steam systems by:
 - Operating more backpressure turbines than necessary
 - Poor control strategies
 - The low-pressure vent should always be a point of investigation
 - From the physical site operations standpoint
 - From the MEASUR model standpoint

Example Steam System – Pulp & Paper Mill

- One final modification


- The pulp and paper mill has one condensing steam turbine to produce just enough power to allow for a safe shutdown of the mill during a power issue from the grid
- Condensing turbine efficiency = 80%
- Steam flow rate = 5.0 klb/hr
- High Pressure header steam usage = 3 klb/hr

TURBINE DETAILS

Condensing Turbine

Isentropic Efficiency	80	%
Generator Efficiency	95	%
Condenser Pressure	1	psia
Operation Type	Steam Flow	▼
Fixed Flow	5	klb

MEASUR – Pulp & Paper Mill Model



MEASUR – Pulp & Paper Mill Model

COST SUMMARY

Power Balance	
Generation	499.6 kW
Demand	5,499.6 kW
Import	5,000 kW
Unit Cost	\$0.05 /kWh
Total \$/yr	\$2,190,000

Fuel Balance	
Boiler	147.05 MMBtu/hr
Unit Cost	\$5.00 /MMBtu
Total \$/yr	\$6,440,979

Make-Up Water	
Flow	95.65 gpm 50,272,661.49 gal
Unit Cost	\$0.01 /gal
Total \$/yr	\$502,727

Total Operating Cost	
	\$9,133,705

MARGINAL STEAM COST

High Pressure	\$9.04 /klb
Medium Pressure	\$9.04 /klb
Low Pressure	\$9.04 /klb

Better Plants Diagnostic Equipment Program (DEP)

- **Steam System Assessment Portable Tools**

Field Measurements


- Usually energy experts can do these over short durations (1 or 2 days)
- Use of portable instrumentation is a good way to back up findings
- Portable Measurements can help to build credibility in existing in-situ instruments for accuracy



Field Measurements (Caution!)

- Instantaneous measurements
- Historical data
- Measurements over time interval


Data Gathering – Snapshot or Movie?



Combustion Flue gas Analyzer

- Main purpose – Combustion Efficiency, Stack Loss
- Additionally, it provides information on
 - Stack temperature
 - Flue gas O₂, Excess air
 - CO – unburnt fuel
 - CO₂ – generally, a calculated value
 - SO_x, NO_x – depending on the sensors
 - Draft in the stack / furnace
- Standard fuels maybe available in equipment
- Specific fuel information maybe needed

Combustion Flue gas Analyzer




- ✓ Sensor Life (1.5-2 years)
- ✓ Location of reading
- ✓ Remember – Dry basis measurement

Infra-Red Thermographic Camera

- Main purpose – Heat Loss, Surface Temperature
- Additionally, it can be used for
 - Safety
 - Validating temperature sensors
 - Operation of steam traps
 - Boiler shell loss evaluation
 - Electrical equipment protection
- Different models
- Software may or may not be needed



Infra-Red Thermographic Camera



- ✓ Type of image
- ✓ Remember to Focus
- ✓ Emissivity; Scale Setting

Thermometer with Probes

- ✓ Can have applications where a bulk temperature needs to be measured
 - Condensate, Make-up water
 - Process fluid in a tank
 - Waste / effluent





Water Conductivity Meter

- ✓ Used for feedwater and blowdown conductivity measurement
 - TDS (ppm)
- ✓ Calibrate with distilled water



Ultrasonic Leak Detector

- ✓ Monitors the acoustic signal of flow through orifice
 - Steam traps
 - Leaks in valves



Pitot Tubes w/dP Gage / Manometer

- ✓ Can be used for measuring flow in different places
 - Air flow in duct
 - Steam venting from pipe
 - Leaks
- ✓ Water-filled manometer can be used also instead of dP gage



Other Essentials

- ✓ Safety Equipment
 - PPE
- ✓ Digital camera
- ✓ Stop watch
- ✓ Batteries / Chargers



Better Plants Diagnostic Equipment Program (DEP)



Diagnostic Equipment Program (DEP)

The Better Plants **Diagnostic Equipment Program (DEP)** allows partners to borrow over 22 different kinds of tools to collect energy data and improve equipment performance in their facilities.

Through this program, partners have the opportunity to test tools firsthand before deciding to purchase a piece of equipment on their own. This not only allows for the improved testing and collection of energy data, but also helps to demonstrate the value of certain tools in different applications throughout a facility.

EXPLORE SOME OF THE TOOLS THAT YOU CAN BORROW THROUGH BETTER PLANTS:

POWER LOGGER



This device helps you directly measure energy consumption, which can be converted into costs. It also logs data to provide electric consumption trends.

CURRENT TRANSFORMER



Use this device with a data logger to quantify the electric current flowing to a component or system and identify wasted energy.

COMBUSTION ANALYZER



This analyzer quantifies excess oxygen in boilers and combustion process exhausts, helping you save fuel and heat energy.

LEAK DETECTOR




This device helps you identify leaks in compressed air or steam systems using high frequencies that are undetectable to the human ear.

FULL SUITE OF DIAGNOSTIC TOOLS

- Anemometer
- Combustion Analyzer
- Conductivity Meter
- Current Transformer
- Digital Manometer
- Digital Thermometer
- Infrared Camera
- Infrared Thermometer
- Laser Distance Meter
- Light Meter
- Pitot Tube
- Power Logger
- Pressure Transducer
- Pyrometer
- Sonic Imager
- Strobe Tachometer
- Temp/RH logger
- Thermocouple
- Thermocouple Logger
- Time of Use Logger
- Ultrasonic Flow Meter
- Ultrasonic Leak Detector

EXPLORE THE FULL SUITE OF DIAGNOSTIC EQUIPMENT AND SUBMIT AN APPLICATION:



Scan the QR Code above, or click here to download the DEP rental application.

Send this completed form to the Better Plants Diagnostic Equipment Program Manager, Daryl Cox at coxdf@oml.gov.

HAVE QUESTIONS ABOUT BORROWING EQUIPMENT?



Scan the QR code above, or click here to email Daryl Cox, DEP Program Manager.

Daryl Cox has over 20 years of experience managing industrial technology and equipment and can help you find the right tool for your energy needs.



betterbuildingsolutioncenter.energy.gov/better-plants/diagnostic-tools



@BetterPlantsDOE



[linkedin.com/showcase/better-plants](https://www.linkedin.com/showcase/better-plants)

Polling Question 3

Polling Question

- 3) Will you be requiring the Better Plants Diagnostic Tools for your plant's steam energy assessment?
- A. Yes, probably most of them
 - B. Maybe only one or two
 - C. None at all
 - D. Don't know yet

Homework #4

- Complete an end-user steam mass balance by individual header level for your plant. Ensure that you have accounted for all significant steam energy users which should total >85% of your total steam usage.
- Complete your steam system model from Homework #3 to more accurately represent your steam balance and your plant operations. If you want create two or at most three models to account for seasonality, production schedules.
- Compare actual steam generation by your boiler to steam generated as per the MEASUR steam system model.
- Compare your fuel costs with your plant's actual fuel costs.
- Use your plant's utility costs to calculate your marginal steam cost (\$/klb)
- Save the file as BaseModel on your computer and send us the .json file

Thank You all for attending today's webinar.

See you all on Wednesday – October 30, 2024 – 10 am ET

If you have specific questions, please stay online and we will try and answer them.

Alternately, you can email questions to me at paparra@ornl.gov