


Rename Yourself to be your Real Name (Company Name)

1. Click on Participant list
2. Go to the right and hover over your name
3. Select “More” & “Rename”
4. Enter your company name in brackets
5. Turn on your camera 😊



Rename [X]

Enter a new screen name:

☒ Remember my name for future meetings

OK **Cancel**

General Information

- Schedule: Every Tuesday (June 3rd – July 8th) morning @ 10am ET
- Sessions will be recorded
- We want these VT to be interactive!
- We're hoping you finish the VT with some big progress
- There will be homework – just try your best!
 - “You’ll get out what you put in!”

Links:

<https://bptraining.ornl.gov/>

<http://betterbuildingsolutioncenter.energy.gov/better-plants>

<https://measur.ornl.gov>





Virtual Training: Onsite Energy Generation and Storage

Exploring Onsite Energy For Your Facility

Session #2

June 10, 2025

10:00am – 12:00pm EST

Training Overview

1. 06/03: Introduction to Onsite Energy Generation
2. 06/10: Exploring Onsite Energy For Your Facility
3. 06/17: Evaluating an Onsite Energy System
4. 06/24: Onsite Energy Success Stories and Overview Of Geothermal Systems
5. 07/01: Overview of Combined Heat and Power, Onsite Biomass, and Small Modular Reactors
6. 07/08: Considerations for Onsite Energy and Renewable Energy Supply Options

Agenda



- 1 ▪ Homework Discussion and Recap
- 2 ▪ Introduction to Onsite Energy Technologies: Solar, Wind Power, and Battery Storage
 - *Indraneel Bhandari, ORNL*
- 3 ▪ PVWatts Demonstration
- 4 ▪ Q&A
- 5 ▪ Homework Assignment
- 6

Review of Session #2 Homework

- Complete the utility bill information and find your facility roof or ground space for PV solar.
 - Retrieve facility address and usable roof/ground space
 - Collect Electric bills for your facility
 - Complete the utility bill exercise (Excel)



Review of Session #2 Homework

- 2360 Cherahala Blvd, Knoxville, TN 37932
 - 1,845,968 kWh
 - 15,000 SF roof space



Review of Session #2 Homework

- Automotive Facility in Michigan
 - 2,151,156 kWh per annum
 - Average Demand 390 kW and Peak Monthly Demand 516 kW



Review of Session #2 Homework




- Automotive Facility in Michigan
 - 2,151,156 kWh
 - 47,916 SF of vacant land available
 - 230,000 SF landscape and parking lot
 - Roof determined to be unsuitable to support solar panels



Review of Session #2 Homework


■ Submission #2

- 4,915,365 kWh per annum
- Average Demand 782 kW and Peak Monthly Demand 1,062 kW



Review of Session #2 Homework

- Submission #3: Iron & Steel Plant in Ohio
 - 33M KWh if operating 30 days with no Maintenance Outages
 - 26M to 28M KWh during some months that include 3-4 days down for maintenance
 - 1,132,560 SF (26 acres) of vacant land available
 - 90,000 SF roof
 - Roof determination and site constraints




138kv utility feed

2400 volt 3-phase
Delta circuit feed


Review of Session #2 Homework

- Submission #4: Automotive Parts Facility
 - 21,035,458 kWh per annum
 - Average Demand 3,440 kW and Peak Monthly Demand 4,042 kW


Electric Utility Bills



Monthly Peak Demand kW



Fuel Cost and Usage





Exploring Onsite Energy For Your Facility

Indraneel Bhandari
Oak Ridge National Laboratory



Acknowledgements

- U.S. Department of Energy, Industrial Technologies Office (ITO)
- Christine Holland, PNNL, Economist
- Andy Walker, NREL, Senior Research Fellow
- Jennifer King, NREL, Senior Researcher
- Paul Lemar, ORNL




Roadmap for Implementing Onsite Energy Projects



Adapted from US Environmental Protection Agency, 2018, Guide to Purchasing Green Power: Renewable Electricity, Renewable Energy Certificates, and On-site Renewable Generation.
https://www.epa.gov/sites/production/files/201601/documents/purchasing_guide_for_web.pdf

Benefits of Onsite Energy



Roadmap for Implementing Onsite Energy Projects



Adapted from US Environmental Protection Agency, 2018, Guide to Purchasing Green Power: Renewable Electricity, Renewable Energy Certificates, and On-site Renewable Generation.
https://www.epa.gov/sites/production/files/201601/documents/purchasing_guide_for_web.pdf

Poll Time!

U.S. Electricity Demand Rise



Commercial Sector



Information Technology



Fleets and Transportation




Residential Sector



Manufacturing Sector

U.S. electricity consumption (1990–2026)
billion kilowatthours



Demand is Rising



U.S. Electricity Demand Rise



Commercial Sector



Information Technology



Fleets and Transportation



Residential Sector




Manufacturing Sector

U.S. electricity sales to ultimate customers (2020–2026)

change since 2020, billion kilowatthours

Short-Term Energy
Outlook forecast




Demand is Rising



PV, Wind, and Battery Storage

U.S. electric generating capacity (2020–2026)
change since 2020, gigawatts



Solar Energy

Solar Energy Technologies

Electricity

- Photovoltaic (PV)
- Concentrated Solar Power (CSP)

Thermal Applications

- Solar Hot Water Systems
- Solar Space Heating and Cooling
- Solar Process Heat



Solar PV




CSP



Evacuated Tube Solar Hot Water Collectors (up to 750°F)




Parabolic Solar Trough




Transpired Air Collectors
(Solar preheating for ventilation air)

Solar Resource

- **Irradiance:** Incoming solar radiation received per unit area (W/m^2)
- **Direct Normal Irradiance (DNI):** Solar radiation received directly from the sun on a surface perpendicular to the sun's rays; used for concentrating solar power systems.
- **Diffuse Horizontal Irradiance (DHI):** Solar radiation scattered by the atmosphere and received from all directions on a horizontal surface (equally).
- **Global Horizontal Irradiance (GHI):** Total solar radiation received on a horizontal surface, including both DNI (projected) and DHI (scattered)



PV Cells



How Solar PV Technology Works?

- Concept
- Main components
 - Panels
 - Inverter
 - Battery
 - Distribution
- Nameplate capacity rating (kW_{dc} & kW_{ac})





Image Source: <https://www.linkedin.com/pulse/what-solar-energy-how-do-panels-work-blue-jay-technology-co-ltd/>


Alternating Current (AC) PV System with Inverter



Graphic by Andy Walker, NREL


Different Inverter Arrangements:
Central Inverter
String Inverter
Micro-inverter (on each PV Module)
DC Optimizer

Solar PV is Modular




Type of Solar PV Installations

1. Distributed Generation (Distributed Energy Resources, DER)
 - a) Residential (3 - 10 kW)
 - b) Commercial/Industrial (10 kW - 2 MW)
2. Utility-scale Generation (> 2 MW)



Ground Mounted



Rooftop Mounted

Source: NREL, 2016. Facility-Scale Solar Photovoltaic Guidebook

Type of Solar PV Orientations

Fixed Tilt



Image Source: PVCase.com

Single-Axis Tracker



Image Source: Arctech

Now with Bi-Facial Panels

Type of Solar PV Orientations: Dual-Axis




Image Source: Chaowanan et al. 2020 <https://doi.org/10.1016/j.seta.2019.100618>.



Image Source: <https://www.solarcentex.com/>

Type of Solar PV Orientations: Vertical

With Bi-Facial Panels




Image Source: PVMagazine



Image Source: Next2Sun

PV Module Nameplate

Mechanical Specifications



Series 6 Plus.

Electrical Specifications

RATINGS AT STANDARD TEST CONDITIONS (1000W/m², AM 1.5, 25°C)²

SERIES 6 PLUS SL MODEL TYPES: FS-6XXX-P-I / FS-6XXXA-P-I

SERIES 6 PLUS HL MODEL TYPES: FS-6XXX-P / FS-6XXXA-P (XXX = NOMINAL POWER)

| | | | | | | | |
|-------------------------------------|----------------------|-------|-------|-------|-------------------|-------|-------|
| Nominal Power ³ (-0/+5%) | P _{MAX} (W) | 455 | 460 | 465 | 470 | 475 | 480 |
| Efficiency (%) | % | 18.1 | 18.3 | 18.5 | 18.7 | 18.9 | 19.0 |
| Voltage at P _{MAX} | V _{MAX} (V) | 187.8 | 188.8 | 189.8 | 191.1 | 191.5 | 192.8 |
| Current at P _{MAX} | I _{MAX} (A) | 2.42 | 2.44 | 2.45 | 2.46 | 2.48 | 2.49 |
| Open Circuit Voltage | V _{OC} (V) | 222.0 | 222.9 | 223.8 | 224.3 | 224.8 | 225.4 |
| Short Circuit Current | I _{SC} (A) | 2.58 | 2.59 | 2.60 | 2.61 | 2.61 | 2.62 |
| Maximum System Voltage | V _{SYS} (V) | | | | 1500 ⁵ | | |
| Limiting Reverse Current | I _R (A) | | | | 5.0 | | |
| Maximum Series Fuse | I _{CF} (A) | | | | 5.0 | | |

RATINGS AT NOMINAL OPERATING CELL TEMPERATURE OF 45°C (800W/m², 20°C AIR TEMPERATURE, AM 1.5, 1m/s WIND SPEED)²

| | | | | | | | |
|-----------------------------|----------------------|-------|-------|-------|-------|-------|-------|
| Nominal Power | P _{MAX} (W) | 343.6 | 347.3 | 351.3 | 355.0 | 358.8 | 362.4 |
| Voltage at P _{MAX} | V _{MAX} (V) | 176.2 | 176.3 | 177.4 | 179.3 | 179.4 | 180.3 |
| Current at P _{MAX} | I _{MAX} (A) | 1.95 | 1.97 | 1.98 | 1.98 | 2.00 | 2.01 |
| Open Circuit Voltage | V _{OC} (V) | 209.6 | 210.4 | 211.3 | 211.8 | 212.3 | 212.7 |
| Short Circuit Current | I _{SC} (A) | 2.08 | 2.09 | 2.10 | 2.10 | 2.11 | 2.11 |

TEMPERATURE CHARACTERISTICS

| | | |
|---|------------------------------------|---|
| Module Operating Temperature Range | (°C) | -40 to +85 |
| Temperature Coefficient of P _{MAX} | T _K (P _{MAX}) | -0.32%/°C [Temperature Range: 25°C to 75°C] |
| Temperature Coefficient of V _{OC} | T _K (V _{OC}) | -0.28%/°C |
| Temperature Coefficient of I _{SC} | T _K (I _{SC}) | +0.04%/°C |

Certifications & Tests⁴

CERTIFICATIONS & LISTINGS

IEC 61215:2021 & 61730-1:2016⁵, CE
IEC 61701 Salt Mist Corrosion
IEC 60068-2-68 Dust and Sand Resistance
UL 61730 1500V Listed

EXTENDED DURABILITY TESTS

IEC TS 63209-1 Extended Stress Test
Long-Term Sequential
Thresher Test
PID Resistant

QUALITY & EHS

ISO 9001:2015
ISO 14001:2015
ISO 45001:2018
ISO 14064-3:2006
EPEAT Silver Registered




Capacity Factor (CF)

- Capacity Factor (CF) is a ratio of energy (kWh or MWh)

$$CF = \frac{\text{actual electricity production}}{\text{modeled production}}$$

- Capacity = Maximum Power Output (kW or MW)



**Resource
Based System
Performance
Indicator**



Key System Performance Indicators: Availability (A) and Performance Ratio (PR)

$$A = \frac{\text{total time} - \text{downtime}}{\text{total time}}$$

- “Information categories” for reporting status IEC 63019-1: 2019:
 - “Raw availability” versus exclusions (e.g., force majeure, utility outage, snow coverage)
 - High-resolution (e.g., hourly, daily) data and reporting required for accurate estimate of Availability

$$PR = \frac{\text{measured production}}{\text{modeled production}}$$

- Measured production
 - Production meter: 15-minute; hourly; monthly.
- Modeled production (IEC 61724-1)
 - Detailed System Description (PV modules, inverter)
 - Coincident Climate (solar and temperature) data
 - Simulation by SAM.nrel.gov or other programs



Walker, Andy, and Desai, Jal. *Understanding Solar Photovoltaic System Performance: An Assessment of 75 Federal Photovoltaic Systems*. United States: N. p., 2021. Web. doi:10.2172/1838130.

**System
Performance
Indicators**

Source: Andy Walker, NREL


Solar PV Performance

Global Horizontal Solar Irradiance (GHI) - kWh/m²/day

GHI @ Arizona = **5.5 – 6.0** kWh/m²/day

GHI @ Minnesota = **3.0 – 3.5** kWh/m²/day

1. **Geographical location:** PV systems perform better in the Southwestern US
2. **Time of day:** Day vs night hours
3. **Season:** Summer vs winter
4. **Local landscape:** Terrain; flat plains, hills, mountains, forests.
5. **Local weather:** Number of days cloudy vs days sunny



Source: NREL, 2018. NSRDB: National Solar Radiation Database

Integration of PV into Energy System



Building Level

- Sizing of Electrical System to Building
- Overcurrent Protection on Electrical Service
- Voltage Regulation
- Power Factor



Substation Level

- Substation bus arrangement, intertie




Grid Level

- Voltage Stability of Electric Grid
- Fault detection and interruption



Generation

- Ramp Rates
- Spinning Reserve



Utility Economics


- Allocating Costs and Resources

PV Solar System Costs

Total Installed Costs for PV Systems by Scale


*Installed Costs only

| System Scale | Size | Mounting | Orientation | Cost (\$/kW) |
|--------------------------------------|--------|----------|----------------------|--------------|
| Medium Commercial / Small Industrial | 200 kW | Rooftop | Fixed Tilt | \$1,860 |
| Large Commercial / Industrial | 3 MW | Ground | Fixed Tilt | \$1,656 |
| | | | Single-Axis Tracking | \$1,822 |
| Utility | 200 MW | Ground | Single-Axis Tracking | \$1,161 |



PV Solar System O&M Costs

Q1 2023 U.S. PV cost benchmarks



Source: Ramasamy, Vignesh, Jarett Zuboy, Michael Woodhouse, Eric O'Shaughnessy, David Feldman, Jal Desai, Andy Walker, Robert Margolis, and Paul Basore. 2023. U.S. Solar Photovoltaic System and Energy Storage Cost Benchmarks, With Minimum Sustainable Price Analysis: Q1 2023. Golden, CO: National Renewable Energy Laboratory. NREL/TP7A40-87303. <https://www.nrel.gov/docs/fy23osti/87303.pdf>.

Decisions Affecting PV System Cost and Performance

Equipment Selection

Siting Considerations

System Types

Module Rack

Inverter Topology

Wire Management

Vegetation



Hail Testing



Inverter Testing




Roof Mount




Ground Mount




Carport



Ballasted Rack



Attached Rack



Micro-inverter



String Inverter



Central Inverter



Wire ties



Connectors



Conduit Raceway



Direct-bury

Summary: Photovoltaics for Industrial Applications

- What makes a site a good fit for this technology?
 - Available area on new roof (or land area)
 - Adequate electrical service
 - High Utility Rates and Tariff Schedule Details
 - Favorable Utility, State, and Local Policies
 - Corporate goals and on-site champion
 - Adequate solar resource
- When should a site consider this technology?
 - New building or new roof project

Rules of Thumb

Cost: \$1500/kW

O&M Cost: \$15/kW/year

Efficiency: 20%

Roof Area: 100 sf/kW

Land Area: 3-6 Acres/MW

Energy: 1500 kWh/kW/year

Capacity Factor: 0.17


Hours/day: 5 hours

Performance Ratio: 85%

5 Minute Break

Wind Energy

Brief History of Wind Turbines



Wind Energy Technologies

System Variations

- Axis orientation
- Tower height
- Rotation capabilities
- Blade counts and orientations




Horizontal Axis Wind Turbine




Vertical Axis Wind Turbine

Increasing Hub Heights



Hub and Nacelle



Wind Turbines Operation

- The rotor (hub and rotor blade assembly) captures wind that creates torque (rotational force) that spins a low-speed shaft
- The gearbox increases the shaft speed which turns a generator
- The generator produces electricity
- Multiple turbines are connected to form a wind farm
 - Wind farm design should consider turbine to turbine spacing

Wind turbine – inside view






Image Source: Siemens Stiftung Media Portal

Wind Turbines Operation


- Size of the Blades ~ **Wind-Swept Area = More Energy**
- Generator Capacity = **Rating (kW or MW)**



Wind Power Curve



- Below Rated Speed
 - Operate at maximum power coefficient
 - Optimum power tracking
- Above Rated Wind Speed
 - Limit power output to grid
 - Limit turbine loads

Power increases with the cube of the wind speed




Wind Turbines: Specific Power

$$\textit{Specific Rating or Specific Power} = \frac{\textit{Generator Size}}{\textit{Blade Size (Wind Swept Area)}}$$



Wind Turbine Size

- Transportation constraints for land-based deployment
- Offshore turbines are much larger than land-based turbines
- Fewer installation and transportation constraints offshore
- Larger turbines lower project costs
 - Fewer turbines are cheaper to maintain
 - Wind speeds higher at taller heights
- No hard limits to further turbine growth*



Source: NREL, <https://www.nrel.gov/docs/fy07osti/42005.pdf>

Siting Wind Power

Location Considerations

- Load Proximity
- Local Zoning and Regulations
- Community Stakeholders
- Maintenance Access
- Interconnection and Grid


Setbacks

- Roads
- Property Lines
- Noise
- Wildlife and Airspace
- Radar Interference



Shared Infrastructure
will help with project
costs and delivery

Rule of thumb:
1.1 Times Tip Height
(top of blade) exclusion

Obstruction of the Wind by a Building or a Tree of Height (H)




Wind in USA



Sources: EIA-860 2022 Early Release, Berkeley Lab

Sources: ACP, U.S. Wind Turbine Database, AWS Truepower, Berkeley Lab, [Land-Based Wind Market Report: 2024 Edition](#)

Distributed Wind Costs



| Parameter | Wind Turbine Class | | | Units |
|--------------------|--------------------|------------|-------|----------|
| | Residential | Commercial | Large | |
| Wind turbine CapEx | 3,823 | 3,723 | 2,392 | \$/kW |
| BOS CapEx | 4,602 | 2,604 | 878 | \$/kW |
| Total CapEx | 8,425 | 6,327 | 3,270 | \$/kW |
| OpEx | 39 | 39 | 39 | \$/kW/yr |

- BOS component cost estimates are obtained from the LandBOSSE model (Eberle et al. 2019).
- Because CapEx data are scarce for distributed wind projects, further cost details on the individual system components are not presented.
- OpEx market data are not widely available for distributed wind projects; therefore, \$39/kW/yr is assumed for each wind class and is aligned with the 2023 ATB atb.nrel.gov.


Wind Performance

Annual Average Wind Speed- m/sec

Kansas = **6.0 – 7.9** m/sec @ 60 meters

Florida = **3.0 – 4.9** m/sec @ 60 meters

1. **Altitude:** Wind speeds are higher at greater heights
2. **Time of day:** Day vs night hours
3. **Season:** Summer vs winter
4. **Local landscape:** Terrain; flat plains, hills, mountains, forests.
5. **Local weather:** Share of time the wind is blowing




Source: NREL, 2018.

Battery Storage


Battery Electric Storage Systems or BESS

- Electrochemical
- Defined Power and Energy Capacity
- Rechargeable
- On-demand or as needed




Battery Electric Storage Systems or BESS

- Duration (hrs.)
- Degradation (1 - 3% /year)
- Depth of discharge (% DOD)
- State of charge (SOC)
- Cycle life
- End-of-life
- Round trip efficiency (RTE)
- Calendar life
- Second life



Load Factor (LF)

- Peak Load = Maximum Power Demand (kW or MW)



$$\begin{aligned} LF &= \text{Consumption} / (\text{Peak Load} \times \text{Hours}) \\ &= 22325 \text{ kWh} / (1550 \text{ kW} \times 24 \text{ hr}) \\ &= 0.60 \end{aligned}$$

$$LF = \frac{\text{Average Load (kW or MW)}}{\text{Peak Load (kW or MW)}}$$

- Average Load (kW or MW) = Total Consumption (kWh or MW) divided by the hours in period (hours)




**Facility
Consumption
Indicator**

BESS Applications

- Energy Arbitrage
- Understanding billing structure
 - Demand Charges (\$/kW)
 - Large differential between TOU rates
- Consumption Profiles
 - Assess facility Load Factor




Batteries alone cannot reduce overall consumption, only shift load
=> peak shaving and load flexibility

Example TOU Rates




BESS Applications

- Integrate Other Onsite Energy




Grid Stability with Different Generation Mixes



BESS Applications

■ Integrate Other Onsite Energy



Reduce marginal demand

Reduce
marginal
emissions

Smooth intraday variability

Reduce
consumption
using onsite
sources


BESS Applications

- Emergency Generation
 - High instances of **outages**; extreme weather events
 - Provides **energy back-up** with and without renewable energy.
 - Size your system according to desired length of outage and to the capacity factor of the supply origin (i.e., solar, CHP)
- Power Quality Improvements
 - Mitigation of power fluctuations by providing **voltage regulation**.
 - Nearly instantaneously inject or absorb electricity from or into the grid to stabilize voltage irregularities.
 - **Frequency regulation** by adjusting charging and discharging rates, ensuring a consistent power supply.
 - **Black start capability** by providing immediate power ensuring faster system stabilization.
 - May be able to provide grid services (such as **ancillary services**) in partnership with utilities


Battery Electric Storage Types

| Characteristic | Lithium-ion | Flow | Thermal (high temperature) |
|------------------------|---|---|---|
| Energy Storage Conduit | Energy is stored in electrode material with 6 different cathode materials: iron phosphate (LFP), cobalt oxide, manganese oxide, nickel manganese (NMC) cobalt oxide, titanate, and nickel cobalt aluminum oxide; with LFP and NMC being most common | Electrolytes flow through one or more electrochemical cells from one or more tanks. Three battery types: conventional, hybrid, and membrane-less, with the two most common being vanadium redox and zinc-bromide hybrid | Molten salt - typically use a sodium-sulfur compound, operating at temperatures around 300 – 700° Celsius, releasing stored energy as either heat or electricity. Designed for rapid use and extreme temperatures (e.g., well suited to the aerospace industry) |
| Development Stage | Widely commercialized | Early commercialization | Early commercialization |
| Lifespan (# of cycles) | Depends upon cycling – if cycled everyday may only last 8 years. (1,000-2,500) Calendar life ≈16 years | Unlimited battery cycle life – can be cycled everyday up to 30 years. (12,000-14,000) | Approximately 20 years (approximately 10,000) |
| Duration | Most common is 4 hours | Commonly up to 10 hours | 10-15 minutes |
| Cost (\$/kWh) | \$360 - \$575 | \$356 - \$836 | \$69 - \$155 |
| Storage Efficiency | 86% | 90-95% | 75-99% |


Battery Electric Storage System Components



Battery Electric Storage System Components



The main configuration of ESS



PMS(Power Management System)

- Monitor and estimate power consumption and active operation
- A real-time information received from PCS to monitor the ESS
- the ESS management according to the host controller command
- Management system history and version
- Faulty condition, remote maintenance for recovery available

PCS(Power Conditioning System)

- Invert DC power stored in batteries to AC power with voltage and frequency of commercial
- Convert AC power to DC and charged in batteries

Power Management
System (PMS)
+
Power Conditioning

Battery

- Electrical energy stored in DC
- Discharge the electrical energy to grid via PCS

Battery Management
System (BMS)

BMS(Battery Management System)

- Monitoring battery's current, voltage, temperature, SOC, devices status
- Exchange information and data to communicate with PCS

Performance Parameters

| Li + | 2021 technology | 2030 technology |
|---------------------|-----------------|-----------------|
| RTE (%) | 83% | 85% |
| Cycle Life (number) | 2400 | 2640 |
| Calendar Life (yrs) | 16 | 16 |
| DOD (%) | 80% | 80% |

Discharge Rate

Higher discharge rates




Greater chemical reactions



More heat expended and energy lost

SOC Impact on Cycles




Temperature Impact on Cycles

1. Cycling ageing @ $\Delta\text{SoC}=10\%-90\%$

1. Influence of the temperature & C-rate ?

Capacity loss @ 1C, 25°C, Cycling SoC window = 10%-90%



@ $\Delta\text{SoC}=10\%-90\%$


→ No real influence of C-rate at 25°C and 45°C when $\Delta\text{SoC}=10\%-90\%$

→ Very sharp capacity loss on the first cycles at 5°C for all C-rates

04/06/2015 Mat4Bat Summer School


Lithium-ion Battery Cost For Commercial Applications

- Opportunity for utility partnership/creative financing
 - BESS is expensive, but broader cost considerations make them more attractive
- Capital costs are forecasted to decrease
 - Based on NREL's Annual Technology Baseline forecast costs are expected to decline by 16% through 2030 (most conservative case).



Lithium-ion Battery Cost For Commercial Applications

$$\text{Total System Costs (\$/kW)} = \frac{\left(\text{Battery Pack Cost} \left(\frac{\$}{\text{kWh}} \right) * \text{Battery Energy Capacity (kWh)} \right) + \left(\text{Battery Power Capacity (kW)} * \text{BOS Cost} \left(\frac{\$}{\text{kW}} \right) \right) + \text{Battery Power Constant (\$)}}{\text{Battery Power Capacity (kW)}}$$



Rule of Thumb:
\$400/kWh plus
operation costs

Wrapping Up!

Partners Case Studies

Volvo's powertrain facility at Hagerstown, MD:

- I. July 2015 – Solar canopy for the entire plant's parking lot with 5,000 solar panels (1.3 MW capacity).
- II. May 2016 – Ground mount solar PV panels, 2,094 kW capacity, covers 50% of the plant's electricity via PPA.

VOLVO
VOLVO GROUP



Solar canopy in the parking lot



Ground mounted solar PV system

Partners Case Studies

The Estée Lauder Companies ...

In 2020, The Estée Lauder Companies added 3.8 MW of solar power at the corporation level to bring the global company's total to more than 5 MW of solar capacity. In the United States, a 1.45 MW ground-mounted solar array was installed in their Melville, New York site. This project is expected to produce more than 1,800 MWh/year of solar power and reduce 1,300 MT of CO₂ emissions annually. Also, at the Blaine, Minnesota facility, around mid-2020, the installation of 900-kW (3.6-acre) solar PV array was completed to supply 50% of the manufacturing facility's annual demand.

ESTÉE
LAUDER
COMPANIES



**"3.8 MW of
solar power
was added
in 2020"**



Melville, New York



Blaine, Minnesota

CalPortland ... Cement Plant

CalPortland signed a PPA for 24 MW wind turbine generation facility that consists of eight 3 MW wind turbines—as part of the Alta Wind Energy Center—to directly supply electricity to its Mojave cement plant. The 24 MW wind farm generates around 40,000 MWh annually, which covers 20% of the plant electricity consumption.

**"24 MW wind
turbine generation
facility, 40,000
MWh/year"**



CALPORTLAND®



Part of the Alta Wind Energy Center near CalPortland's cement plant in Mojave, CA

Other Resources:

- [Onsite Energy Program](#)
- [Better Plants Solutions Center](#)
- [Federal Battery Storage Tax Credit](#)
- [State-Level Incentives](#)
- [General Energy Storage Facts](#)
- [U.S. Solar Photovoltaic System and Energy Storage Cost Benchmarks](#)
- [Energy Storage Cost and Performance Database](#)
- [DOE Factsheets on Energy Storage](#)
- [DOE Factsheets on Distributed Wind Power](#)
- [DOE Factsheets Solar Photovoltaic Panels For Industrial Applications](#)
- [Grid-scale Energy Storage Technologies Primer – NREL](#)
- [2024 Electricity ATB Technologies and Data Overview](#)

PVWatts Demo

PVWatts Calculator

- Go to <https://pvwatts.nrel.gov/>



PVWatts[®] Calculator



NATIONAL RENEWABLE ENERGY LABORATORY

Get Started:

English
Español
Українська

HELP

FEEDBACK



NREL's PVWatts[®] Calculator

Estimates the energy production of grid-connected photovoltaic (PV) energy systems throughout the world. It allows homeowners, small building owners, installers and manufacturers to easily develop estimates of the performance of potential PV installations.



PVWatts Calculator

- Go to <https://pvwatts.nrel.gov/>

Help and Documentation



PVWatts Calculator

1. Enter facility address here



The screenshot shows the NREL PVWatts Calculator website. At the top, the title "PVWatts® Calculator" is on the left and the NREL logo is on the right. Below the title, there is a "Get Started:" section with a text input field labeled "Enter a Home or Business Address" and a blue "GO »" button. To the right of the input field are links for "English", "Español", and "Українська". Further right are "HELP" and "FEEDBACK" buttons. Below this navigation bar is a large banner with a blue background and a solar panel image at the bottom. On the left of the banner is an orange cross-shaped icon made of squares. To its right, the text reads "NREL's PVWatts® Calculator" followed by a description: "Estimates the energy production of grid-connected photovoltaic (PV) energy systems throughout the world. It allows homeowners, small building owners, installers and manufacturers to easily develop estimates of the performance of potential PV installations."

PVWatts Calculator

My Location

2360 Cherahala Blvd, Knoxville, TN 37932
» Change Location

English
Español
Українська

HELP

FEEDBACK

RESOURCE DATASYSTEM INFORESULTS

SOLAR RESOURCE DATA

The latitude and longitude of the solar resource data site is shown below, along with the distance between your location and the center of the site grid cell. Use this data unless you have a reason to change it.


Solar resource data site

Lat, Lng: 35.97, -84.141.4 mi

Resource Data Map

The blue rectangle on the map indicates the NREL National Solar Radiation Database (NSRDB) grid cell for your location. If you want to use data for a different NSRDB grid cell, double-click the map to move the rectangle. Dragging the rectangle will not move it. If your location is outside the NSRDB area, the map shows pins for the nearest alternate data sites instead of a rectangle. Click a pin to choose the site you want to use. See [Help](#) for details.

MapSatellite



Google

2. After verifying information, click “system Info”



Go to
system info

PVWatts Calculator

My Location

2360 Cherahala Blvd, Knoxville, TN 37932
» Change Location

English
Español
Українська

HELP

FEEDBACK

RESOURCE DATASYSTEM INFORESULTS

Go to resource data

SYSTEM INFO

Modify the inputs below to run the simulation.

DC System Size (kW):

4

i

Module Type:

Standard

i

Array Type:

Fixed (open rack)

i

System Losses (%):

14.08

i

Tilt (deg):

20

i

Azimuth (deg):

180

i

+ Advanced Parameters

RESTORE DEFAULTS

Rooftop Size Estimator

Click below to estimate the system size from your roof area on a map. (optional)

Map

Google

Go to PVWatts results

3. Adjust roof size

Better Plants
U.S. DEPARTMENT OF ENERGY

88


U.S. DEPARTMENT OF
ENERGY

PVWatts Calculator

Rooftop Size Estimator

Click the map below to draw the area to be occupied by the array. The size estimate is based on the area of a horizontal polygon. It does not account for roof tilt and azimuth, or shading.

System Capacity: 173.4 kWdc (1156 m²)



3. Draw system design

4. Click "Save"

RESET

CANCEL

SAVE

PVWatts Calculator

My Location 2360 Cherahala Blvd, Knoxville, TN 37932
» Change Location

English
Español
Українська

HELP FEEDBACK

RESOURCE DATA SYSTEM INFO RESULTS

SYSTEM INFO

Modify the inputs below to run the simulation.

RESTORE DEFAULTS

Go to resource data

Go to PVWatts results

DC System Size (kW): 173.4

Module Type: Standard

Array Type: Fixed (open rack)

System Losses (%): 14.08

Tilt (deg): 20

Azimuth (deg): 180

+ Advanced Parameters

Rooftop Size Estimator

Click below to estimate the system size from your roof area on a map. (optional)

Map | Satellite

5. Review system capacity

6. System details

7. Advanced Parameters cover additional information for specific systems and equipment selection

Advanced Parameters

DC to AC Size Ratio: 1.2

Inverter Efficiency (%): 96

Ground Coverage Ratio: 0.4

Albedo: From weather file

Bifacial: No

Monthly Irradiance Loss (%):

| | |
|-------|---|
| Jan: | 0 |
| Feb: | 0 |
| Mar: | 0 |
| Apr: | 0 |
| May: | 0 |
| June: | 0 |
| July: | 0 |
| Aug: | 0 |
| Sept: | 0 |
| Oct: | 0 |
| Nov: | 0 |
| Dec: | 0 |

PVWatts Calculator

RESULTS

[Print Results](#)

234,210 kWh/Year*

System output may range from 230,088 to 248,075 kWh per year near this location.

[Click HERE](#) for more information.

| Month | Solar Radiation (kWh / m ² / day) | AC Energy (kWh) |
|-----------|---|----------------------|
| January | 3.54 | 15,457 |
| February | 3.84 | 14,807 |
| March | 4.74 | 19,524 |
| April | 5.70 | 21,937 |
| May | 6.13 | 24,054 |
| June | 6.27 | 23,254 |
| July | 6.14 | 23,444 |
| August | 6.03 | 22,984 |
| September | 5.61 | 21,006 |
| October | 4.90 | 19,557 |
| November | 3.66 | 14,873 |
| December | 3.05 | 13,313 |
| Annual | 4.97 | 234,210 |

User Comments

Type here to add optional comments to printout.



Download Results: [Monthly](#) | [Hourly](#)

[Find A Local Installer](#)

* Caution: The PVWatts energy estimate is based on an hourly performance simulation using a typical-year weather file that represents a multi-year historical period for Knoxville, TN for a Fixed (open rack) photovoltaic system. The kWh range is based on analysis of a nearby data site [described here](#).

These results are based on assumptions described in [Help](#) that may not accurately represent technical characteristics of the project you are modeling.

8. Download results

Questions?

Download SAM

<https://sam.nrel.gov/>

Homework #2: Due COB Monday 6/16

Please use the link below to access the *PV Watts Tool* tool to estimate the energy production of grid-connected photovoltaic (PV) energy system for your facility.

- **Data needed** before running the simulation:

1- Address of facility or intended location

Example: 2350 Cherahala Blvd, Knoxville, TN 37932

Please write below your location and estimated system size:

Address: _____

Select Area: Using mouse

System Capacity: ____kW



<https://pvwatts.nrel.gov>

Thank you!